

	Mar-17	Mar-18	Mar-19	NEW TEST DATE
Visual (Pass/Fail)	Pass	Pass	Pass	
Fuse (A)	13	13	13	
Earth Continuity (Ω)	0.054	0.057	0.058	
Insulation Resistance (M Ω)	>300	>300	>300	
Leakage (mA)	<0.30	<0.30	<0.30	