

MEASE DUNEDIN HOSPITAL  
SEMI-ANNUAL RECEPTACLE TEST REPORT

DEPARTMENT: EMERGENCY ROOM 1 CRITICAL CARE

MAY 2013

	LOCATION	RECEPTACLE NUMBER	CIRCUIT TYPE	VISUAL INSP.	POLARITY	TENSION TEST	COMMENTS
1	TV TOP WALL	03CL1S1#1	CR	PASS	PASS	PASS	LOOSE
2	WALL	03CL1S1#3-L	CR	PASS	PASS	PASS	LOOSE
3	WALL	03CL1S1#3-R	CR	PASS	PASS	PASS	LOOSE
4	WALL	03NL1S2#79	GEN	PASS	PASS	PASS	PASS
5	WALL	03NL1S2#79	GEN	PASS	PASS	PASS	LOOSE
6	WALL	03CL1S1#1	CR	PASS	PASS	PASS	PASS
7	WALL	03CL1S1#5,7-L	CR	PASS	PASS	PASS	PASS
8	WALL	03CL1S1#5,7-R	CR	PASS	PASS	PASS	PASS
9	SINK	03NL1S2#77	GEN	PASS	PASS	PASS	LOOSE
10	WALL	03CL1S1#16	CR	PASS	PASS	PASS	PASS
11	WALL	03NL1S2#77	GEN-GFI	PASS	PASS	PASS	PASS
12	TV TOP WALL	NO ID	GEN	PASS	PASS	PASS	PASS

mV OHMS

CIRCUIT TYPE: CR-CRITICAL-LIFE SUPPORT GEN-NORMAL POWER REFERENCE GROUND: COLD WATER PIPE REVISED 7-2012

ASSET #



MD-ED RM 1

SEMI- ANNUAL  
INSPECTION

LOCATION



MD-ED RM 1

MEASE DUNEDIN HOSPITAL  
SEMI-ANNUAL RECEPTACLE TEST REPORT

DEPARTMENT: EMERGENCY ROOM 2 CRITICAL CARE

MAY 2013

	LOCATION	RECEPTACLE NUMBER	CIRCUIT TYPE	VISUAL INSP.	POLARITY	TENSION TEST	COMMENTS
1	WALL	03CL1S1#16	CR	PASS	PASS	PASS	PASS
2	WALL	03CL1S1#13,15-L	CR	PASS	PASS	PASS	PASS
3	WALL	03CL1S1#13,15-R	CR	PASS	PASS	PASS	PASS
4	WALL	NO ID	GEN	PASS	PASS	PASS	PASS
5	WALL	03NL1S2#73	GEN	FAIL	PASS	PASS	CRACKED PLATE
6	WALL	03CL1C1#9	CR	PASS	PASS	PASS	LOOSE
7	WALL	03CL1S1#11-L	CR	PASS	PASS	PASS	PASS
8	WALL	03CL1S1#11-R	CR	PASS	PASS	PASS	PASS
9	WALL	03NL1S2#81	GEN	FAIL	PASS	PASS	CRACKED PLATE
10	WALL	03CL1C1#9	CR	PASS	PASS	PASS	LOOSE
11	WALL	03NL1S2#75	GEN	FAIL	PASS	PASS	CRACKED PLATE
12	TV TOP WALL	NO ID	GEN	PASS	PASS	PASS	PASS
13	SINK	03NL1S2#81	GEN-GFI	PASS	PASS	PASS	PASS

mV OHMS

CIRCUIT TYPE: CR-CRITICAL-LIFE SUPPORT GEN-NORMAL POWER REFERENCE GROUND: COLD WATER PIPE REVISED 7-2012

ASSET #



MD-ED RM 2

SEMI-ANNUAL  
INSPECTION

LOCATION



MD-ED RM 2

MEASE DUNEDIN HOSPITAL  
SEMI-ANNUAL RECEPTACLE TEST REPORT

DEPARTMENT: EMERGENCY ROOM 3

MAY 2013

[illegible]

mV OHMS

CIRCUIT TYPE: CR-CRITICAL-LIFE SUPPORT GEN-NORMAL POWER REFERENCE GROUND: COLD WATER PIPE REVISED 7-2012

**ASSET #**

MD-ED RM 3

## SEMI- ANNUAL INSPECTION

## LOCATION



MD-ED RM 3

MEASE DUNEDIN HOSPITAL  
SEMI-ANNUAL RECEPTACLE TEST REPORT

DEPARTMENT: EMERGENCY ROOM 4

MAY 2013

	LOCATION	RECEPTACLE NUMBER	CIRCUIT TYPE	VISUAL INSP.	POLARITY	TENSION TEST	COMMENTS
1	BATH	NO ID	GEN-GFI	PASS	PASS	PASS	PASS
2	SINK WALL	03NL1S2#16	GEN-GFI	FAIL	PASS	PASS	CRACKED PLATE
3	TV TOP WALL	NO ID	GEN	PASS	PASS	PASS	PASS
4	WALL	03CL1S1#16	CR	PASS	PASS	PASS	LOOSE
5	WALL	03CL1S2#54,56-L	CR	PASS	PASS	PASS	PASS
6	WALL	03CL1S2#54,56-R	CR	PASS	PASS	PASS	PASS
7	WALL	03CL1S2#64	CR	PASS	PASS	PASS	PASS
8	WALL	03NL1S2#69	GEN	PASS	PASS	PASS	PASS
9	WALL	03CL1S2#52-L	CR	PASS	PASS	PASS	PASS
10	WALL	03CL1S2#52-R	CR	PASS	PASS	PASS	PASS

mV OHMS

CIRCUIT TYPE: CR-CRITICAL-LIFE SUPPORT GEN-NORMAL POWER REFERENCE GROUND: COLD WATER PIPE REVISED 7-2012

ASSET #



MD-ED RM 4

SEMI-ANNUAL  
INSPECTION

LOCATION



MD-ED RM 4

MEASE DUNEDIN HOSPITAL  
SEMI-ANNUAL RECEPTACLE TEST REPORT

DEPARTMENT: EMERGENCY ROOM 5

MAY 2013

[illegible]

mV OHMS

CIRCUIT TYPE: CR-CRITICAL-LIFE SUPPORT GEN-NORMAL POWER REFERENCE GROUND: COLD WATER PIPE REVISED 7-2012

ASSET #



MD-ED RM 5

## SEMI- ANNUAL INSPECTION

LOCATION



MD-ED RM 5

MEASE DUNEDIN HOSPITAL  
SEMI-ANNUAL RECEPTACLE TEST REPORT

DEPARTMENT: EMERGENCY ROOM 6

MAY 2013

	LOCATION	RECEPTACLE NUMBER	CIRCUIT TYPE	VISUAL INSP.	POLARITY	TENSION TEST	COMMENTS
1	TV TOP WALL	NO ID	GEN	PASS	PASS	PASS	PASS
2	WALL	NO ID	GEN	PASS	PASS	PASS	PASS
3	WALL	03CL1S1#66	CR	PASS	PASS	PASS	PASS
4	WALL	03CL1S1#78-L	CR	PASS	PASS	PASS	PASS
5	WALL	03CL1S1#78-R	CR	PASS	PASS	PASS	PASS
6	WALL	NO ID	GEN	PASS	PASS	PASS	NEEDS REPAIR
7	WALL	03CL1S1#76,74-L	CR	PASS	PASS	PASS	PASS
8	WALL	03CL1S1#76,74-R	CR	PASS	PASS	PASS	PASS

mV OHMS

CIRCUIT TYPE: CR-CRITICAL-LIFE SUPPORT GEN-NORMAL POWER REFERENCE GROUND: COLD WATER PIPE REVISED 7-2012

ASSET #



MD-ED RM 6

SEMI- ANNUAL  
INSPECTION

LOCATION



MD-ED RM 6

MEASE DUNEDIN HOSPITAL  
SEMI-ANNUAL RECEPTACLE TEST REPORT

DEPARTMENT: EMERGENCY ROOM 7

MAY 2013

	LOCATION	RECEPTACLE NUMBER	CIRCUIT TYPE	VISUAL INSP.	POLARITY	TENSION TEST	COMMENTS
1	WALL	NO ID	GEN	PASS	PASS	PASS	PASS
2	WALL	03NL1S1#46-L	GEN-	PASS	PASS	PASS	PASS
3	WALL	03NL1S1#46-R	GEN-	PASS	PASS	PASS	PASS
4	WALL	03CL1S1#79-L	CR	PASS	PASS	PASS	PASS
5	WALL	03CL1S1#79-R	CR	PASS	PASS	PASS	PASS
6	WALL	03CL1S1#24	CR	PASS	PASS	PASS	PASS
7	WALL	03CL1S1#81,83-L	CR	PASS	PASS	PASS	PASS
8	WALL	03CL1S1#81,83-R	CR	PASS	PASS	PASS	PASS
9	WALL	03NL1S1#43-L	GEN-	PASS	PASS	PASS	PASS
10	WALL	03NL1S1#43-R	GEN-	PASS	PASS	PASS	PASS
11	TV TOP WALL	03CL1S1#44	GEN	PASS	PASS	PASS	LOOSE
12	WALL	03NL1S1#59	GEN	PASS	PASS	PASS	PASS

mV    OHMS

CIRCUIT TYPE: CR-CRITICAL-LIFE SUPPORT GEN-NORMAL POWER    REFERENCE GROUND: COLD WATER PIPE REVISED 7-2012

ASSET #



MD-ED RM 7

SEMI- ANNUAL  
INSPECTION

LOCATION



MD-ED RM 7

MEASE DUNEDIN HOSPITAL  
SEMI-ANNUAL RECEPTACLE TEST REPORT

DEPARTMENT: EMERGENCY ROOM 8

MAY 2013

	LOCATION	RECEPTACLE NUMBER	CIRCUIT TYPE	VISUAL INSP.	POLARITY	TENSION TEST	COMMENTS
1	WALL	03CL1S1#24	GEN	PASS	PASS	PASS	LOOSE
2	WALL	03NL1S1#45-L	GEN-	PASS	PASS	PASS	PASS
3	WALL	03NL1S1#45-R	GEN-	PASS	PASS	PASS	PASS
4	WALL	03CL1S1#73,75-L	CR	PASS	PASS	PASS	LOOSE
5	WALL	03CL1S1#73,75-R	CR	PASS	PASS	PASS	LOOSE
6	WALL	03CL1S1#44	CR	PASS	PASS	PASS	PASS
7	WALL	03CL1S1#77-L	CR	PASS	PASS	PASS	PASS
8	WALL	03CL1S1#77-R	CR	PASS	PASS	PASS	PASS
9	WALL	03NL1S1#48-L	GEN-	PASS	PASS	PASS	PASS
10	WALL	03NL1S1#48-R	GEN-	PASS	PASS	PASS	PASS
11	TV TOP WALL	NO ID	GEN	PASS	PASS	PASS	PASS

mV OHMS

CIRCUIT TYPE: CR-CRITICAL-LIFE SUPPORT GEN-NORMAL POWER REFERENCE GROUND: COLD WATER PIPE REVISED 7-2012

ASSET #



MD-ED RM 8

SEMI- ANNUAL  
INSPECTION

LOCATION



MD-ED RM 8



MEASE DUNEDIN HOSPITAL  
SEMI-ANNUAL RECEPTACLE TEST REPORT

DEPARTMENT: EMERGENCY ROOM 9 CRITICAL CARE

MAY 2013

	LOCATION	RECEPTACLE NUMBER	CIRCUIT TYPE	VISUAL INSP.	POLARITY	TENSION TEST	COMMENTS
1	TV TOP WALL	NO ID	GEN	PASS	PASS	PASS	PASS
2	WALL	03NL1S1#61	GEN	PASS	PASS	PASS	LOOSE
3	WALL	03NL1S1#47-L	GEN-	PASS	PASS	PASS	PASS
4	WALL	03NL1S1#47-R	GEN	PASS	PASS	PASS	PASS
5	WALL	03CL1S1#69,71-L	CR	PASS	PASS	PASS	PASS
6	WALL	03CL1S1#69,71-R	CR	PASS	PASS	PASS	PASS
7	WALL	03CL1S1#46	CR	PASS	PASS	PASS	PASS
8	WALL	03CL1S1#67-L	CR	PASS	PASS	PASS	PASS
9	WALL	03CL1S1#67-R	CR	PASS	PASS	PASS	PASS
10	WALL	03NL1S1#44-L	GEN-	PASS	PASS	PASS	PASS
11	WALL	03NL1S1#44-R	GEN	PASS	PASS	PASS	PASS
12	WALL	03CLC1S1#26	CR	PASS	PASS	PASS	LOOSE

mV OHMS

CIRCUIT TYPE: CR-CRITICAL-LIFE SUPPORT GEN-NORMAL POWER REFERENCE GROUND: COLD WATER PIPE REVISED 7-2012

ASSET #



MD-ED RM 9

SEMI- ANNUAL  
INSPECTION

LOCATION



MD-ED RM 9

MEASE DUNEDIN HOSPITAL  
SEMI-ANNUAL RECEPTACLE TEST REPORT

DEPARTMENT: EMERGENCY ROOM 10

MAY 2013

	LOCATION	RECEPTACLE NUMBER	CIRCUIT TYPE	VISUAL INSP.	POLARITY	TENSION TEST	COMMENTS
1	WALL	03NL1S1#63	GEN	PASS	PASS	PASS	PASS
2	WALL	03NL1S1#52-L	GEN-	PASS	PASS	PASS	PASS
3	WALL	03NL1S1#52-R	GEN-	PASS	PASS	PASS	PASS
4	WALL	03CL1S1#61,63-L	CR	PASS	PASS	PASS	PASS
5	WALL	03CL1S1#61,63-R	CR	PASS	PASS	PASS	PASS
6	WALL	03CL1S1#26	CR	PASS	PASS	PASS	PASS
7	WALL	03CL1S1#65-L	CR	PASS	PASS	PASS	PASS
8	WALL	03CL1S1#65-R	CR	PASS	PASS	PASS	PASS
9	WALL	03NL1S1#49-L	GEN-	PASS	PASS	PASS	PASS
10	WALL	03NL1S1#49-R	GEN-	PASS	PASS	PASS	PASS
11	WALL	03CL1S1#46	CR	PASS	PASS	PASS	PASS
12	TV TOP WALL	NO ID	GEN	PASS	PASS	PASS	PASS

mV OHMS

CIRCUIT TYPE: CR-CRITICAL-LIFE SUPPORT GEN-NORMAL POWER REFERENCE GROUND: COLD WATER PIPE REVISED 7-2012

ASSET #



MD-ED RM 10

SEMI- ANNUAL  
INSPECTION

LOCATION



MD-ED RM 10

MEASE DUNEDIN HOSPITAL  
SEMI-ANNUAL RECEPTACLE TEST REPORT

DEPARTMENT: EMERGENCY ROOM 11

MAY 2013

	LOCATION	RECEPTACLE NUMBER	CIRCUIT TYPE	VISUAL INSP.	POLARITY	TENSION TEST	COMMENTS
1	TV TOP WALL	NO ID	GEN	PASS	PASS	PASS	PASS
2	WALL	03NL1S1#63	GEN	PASS	PASS	PASS	LOOSE
3	WALL	03NL1S1#54-L	GEN-GFI	PASS	PASS	PASS	NO POWER
4	WALL	03NL1S1#54-R	GEN-GFI	PASS	PASS	PASS	NO POWER
5	WALL	03CL1S1#55-L	CR	PASS	PASS	PASS	PASS
6	WALL	03CL1S1#55-R	CR	PASS	PASS	PASS	PASS
7	WALL	03CL1S1#46	CR	PASS	PASS	PASS	PASS
8	WALL	03CL1S1#57,59-L	CR	PASS	PASS	PASS	PASS
9	WALL	03CL1S1#57,59-R -	CR	PASS	PASS	PASS	PASS
10	WALL	03NL1S1#51-L	GEN-GFI	PASS	PASS	PASS	NO POWER
11	WALL	03NL1S1#51-R	GEN-GFI	PASS	PASS	PASS	NO POWER
12	WALL	03CLC1S1#48	CR	PASS	PASS	PASS	LOOSE

mV OHMS

CIRCUIT TYPE: CR-CRITICAL-LIFE SUPPORT GEN-NORMAL POWER REFERENCE GROUND: COLD WATER PIPE REVISED 7-2012

ASSET #



MD-ED RM 11

SEMI- ANNUAL  
INSPECTION

LOCATION



MD-ED RM 11

MEASE DUNEDIN HOSPITAL  
SEMI-ANNUAL RECEPTACLE TEST REPORT

DEPARTMENT: EMERGENCY ROOM 12

MAY 2013

	LOCATION	RECEPTACLE NUMBER	CIRCUIT TYPE	VISUAL INSP.	POLARITY	TENSION TEST	COMMENTS
1	WALL	03NL1S1#65	GEN	PASS	PASS	PASS	LOOSE
2	WALL	03NL1S1#53-L	GEN-	PASS	PASS	PASS	PASS
3	WALL	03NL1S1#47-R	GEN-	PASS	PASS	PASS	PASS
4	WALL	03CL1S1#49,51-L	CR	PASS	PASS	PASS	PASS
5	WALL	03CL1S1#49,51-R	CR	PASS	PASS	PASS	PASS
6	WALL	03CL1S1#28	CR	PASS	PASS	PASS	LOOSE
7	WALL	03CL1S1#53-L	CR	PASS	PASS	PASS	PASS
8	WALL	03CL1S1#53-R	CR	PASS	PASS	PASS	PASS
9	WALL	03NL1S1#50-L	GEN-	PASS	PASS	PASS	PASS
10	WALL	03NL1S1#50-R	GEN-	PASS	PASS	PASS	PASS
11	WALL	03CL1S1#48	CR	PASS	PASS	PASS	PASS
12	TV TOP WALL	NO ID	GEN	PASS	PASS	PASS	PASS

mV    OHMS

CIRCUIT TYPE: CR-CRITICAL-LIFE SUPPORT GEN-NORMAL POWER    REFERENCE GROUND: COLD WATER PIPE REVISED 7-2012

ASSET #



MD-ED RM 12

SEMI- ANNUAL  
INSPECTION

LOCATION



MD-ED RM 12

MEASE DUNEDIN HOSPITAL  
SEMI-ANNUAL RECEPTACLE TEST REPORT

DEPARTMENT: EMERGENCY ROOM 13

MAY 2013

	LOCATION	RECEPTACLE NUMBER	CIRCUIT TYPE	VISUAL INSP.	POLARITY	TENSION TEST	COMMENTS
1	TV TOP WALL	NO ID	GEN	PASS	PASS	PASS	PASS
2	WALL	03NL1S1#65	GEN	PASS	PASS	PASS	LOOSE
3	WALL	03NL1S1#58-L	GEN-GFI	PASS	PASS	PASS	PASS
4	WALL	03NL1S1#58-R	GEN-GFI	PASS	PASS	PASS	PASS
5	WALL	03CL1S1#43-L	CR	PASS	PASS	PASS	PASS
6	WALL	03CL1S1#43-R	CR	PASS	PASS	PASS	PASS
7	WALL	03CL1S1#30	CR	PASS	PASS	PASS	PASS
8	WALL	03CL1S1#45,47-L	CR	PASS	PASS	PASS	PASS
9	WALL	03CL1S1#45,47-R -	CR	PASS	PASS	PASS	PASS
10	WALL	03NL1S1#55-L	GEN-GFI	PASS	PASS	PASS	PASS
11	WALL	03NL1S1#55-R	GEN-GFI	PASS	PASS	PASS	PASS
12	WALL	03CLC1S1#50	CR	PASS	PASS	PASS	LOOSE

mV    OHMS

CIRCUIT TYPE: CR-CRITICAL-LIFE SUPPORT GEN-NORMAL POWER REFERENCE GROUND: COLD WATER PIPE REVISED 7-2012

ASSET #



MD-ED RM 13

SEMI- ANNUAL  
INSPECTION

LOCATION



MD-ED RM 13

MEASE DUNEDIN HOSPITAL  
SEMI-ANNUAL RECEPTACLE TEST REPORT

DEPARTMENT: EMERGENCY ROOM 14

MAY 2013

[illegible]

mV OHMS

CIRCUIT TYPE: CR-CRITICAL-LIFE SUPPORT GEN-NORMAL POWER REFERENCE GROUND: COLD WATER PIPE REVISED 7-2012

**ASSET #**

MD-ED RM 14

## SEMI- ANNUAL INSPECTION

## LOCATION



MD-ED RM 14

MEASE DUNEDIN HOSPITAL  
SEMI-ANNUAL RECEPTACLE TEST REPORT

DEPARTMENT: EMERGENCY ROOM TRIAGE 1

MAY 2013

[illegible]

mV OHMS

CIRCUIT TYPE: CR-CRITICAL-LIFE SUPPORT GEN-NORMAL POWER REFERENCE GROUND: COLD WATER PIPE REVISED 7-2012

**ASSET #**

## MD-ED TRIAGE 1

SEMI- ANNUAL  
INSPECTION

## LOCATION



## MD-ED TRIAGE 1

MEASE DUNEDIN HOSPITAL  
SEMI-ANNUAL RECEPTACLE TEST REPORT

DEPARTMENT: EMERGENCY ROOM TRIAGE 2

MAY 2013

	LOCATION	RECEPTACLE NUMBER	CIRCUIT TYPE	VISUAL INSP.	POLARITY	TENSION TEST	COMMENTS
1	WALL	03CL1S1#39	CR	PASS	PASS	PASS	PASS
2	WALL	NO ID	GEN	PASS	PASS	PASS	PASS
3	WALL	NO ID	GEN	PASS	PASS	PASS	PASS
4	WALL	03CL1S1#25-L	CR	PASS	PASS	PASS	PASS
5	WALL	03CL1S1#25-R	CR	PASS	PASS	PASS	PASS
6	WALL	03CL1S1#27,29-L	CR	PASS	PASS	PASS	PASS
7	WALL	03CL1S1#27,29-R	CR	PASS	PASS	PASS	PASS
8	WALL	03CL1S1#39	CR	PASS	PASS	PASS	PASS
9	WALL	03CL1S1#37	CR	PASS	PASS	PASS	PASS
10	WALL	NO ID	GEN	PASS	PASS	PASS	PASS

mV OHMS

CIRCUIT TYPE: CR-CRITICAL-LIFE SUPPORT GEN-NORMAL POWER REFERENCE GROUND: COLD WATER PIPE REVISED 7-2012

ASSET #



**SEMI- ANNUAL  
INSPECTION**

LOCATION





## MAY 2013

mV OHMS

## LOCATION



MEASE DUNEDIN HOSPITAL  
SEMI-ANNUAL RECEPTACLE TEST REPORT

DEPARTMENT: EMERGENCY ROOM FAST TRACK B

MAY 2013

[illegible]

mV OHMS

CIRCUIT TYPE: CR-CRITICAL-LIFE SUPPORT GEN-NORMAL POWER REFERENCE GROUND: COLD WATER PIPE REVISED 7-2012

**ASSET #**

MD-ED FST TRK B

## SEMI- ANNUAL INSPECTION

## LOCATION



MD-ED FST TRK B

MEASE DUNEDIN HOSPITAL  
SEMI-ANNUAL RECEPTACLE TEST REPORT

DEPARTMENT: EMERGENCY ROOM FAST TRACK C

MAY 2013

[illegible]

mV OHMS

CIRCUIT TYPE: CR-CRITICAL-LIFE SUPPORT GEN-NORMAL POWER REFERENCE GROUND: COLD WATER PIPE REVISED 7-2012

**ASSET #**

MD-ED FST TRK C

## SEMI- ANNUAL INSPECTION

## LOCATION



MD-ED FST TRK C

MEASE DUNEDIN HOSPITAL  
SEMI-ANNUAL RECEPTACLE TEST REPORT

DEPARTMENT: EMERGENCY ROOM FAST TRACK D

MAY 2013

	LOCATION	RECEPTACLE NUMBER	CIRCUIT TYPE	VISUAL INSP.	POLARITY	TENSION TEST	COMMENTS
1	TV TOP WALL	NO ID	GEN	PASS	PASS	PASS	PASS
2	WALL	03CL1C1#2,4-L	CR	PASS	PASS	PASS	PASS
3	WALL	03CL1C1#2,4-R	CR	PASS	PASS	PASS	PASS
4	WALL	NO ID	GEN	PASS	PASS	PASS	PASS
5	WALL	03CL1C1#7	CR	PASS	PASS	PASS	LOOSE
6	WALL	NO ID	GEN	PASS	PASS	PASS	PASS
7	WALL	03CL1C1#6	CR	PASS	PASS	PASS	PASS
8	ACROSS DEFIB	NO ID	GEN	PASS	PASS	PASS	LOOSE
9	ACROSS DEFIB	03CL1C1-10	CR	PASS	PASS	PASS	PASS

mV OHMS

CIRCUIT TYPE: CR-CRITICAL-LIFE SUPPORT GEN-NORMAL POWER REFERENCE GROUND: COLD WATER PIPE REVISED 7-2012

ASSET #



SEMI-ANNUAL  
INSPECTION

LOCATION



MEASE DUNEDIN HOSPITAL  
SEMI-ANNUAL RECEPTACLE TEST REPORT

DEPARTMENT: EMERGENCY ROOM FAST TRACK E

MAY 2013

[illegible]

mV OHMS

CIRCUIT TYPE: CR-CRITICAL-LIFE SUPPORT GEN-NORMAL POWER REFERENCE GROUND: COLD WATER PIPE REVISED 7-2012

**ASSET #**

MD-ED FST TRK E

## SEMI- ANNUAL INSPECTION

## LOCATION



MD-ED FST TRK E

MEASE DUNEDIN HOSPITAL  
SEMI-ANNUAL RECEPTACLE TEST REPORT

DEPARTMENT: EMERGENCY ROOM FAST TRACK F

MAY 2013

[illegible]

mV OHMS

CIRCUIT TYPE: CR-CRITICAL-LIFE SUPPORT GEN-NORMAL POWER REFERENCE GROUND: COLD WATER PIPE REVISED 7-2012

ASSET #



MD-ED FST TRK F

SEMI- ANNUAL  
INSPECTION

LOCATION



**MD-ED FST TRK F**